



Flammables Room Evacuation Plan

In the event that the Flammables Room (Birck 141A) becomes too warm for the chemicals that are stored in this space, the following evacuation plan will be put into place:

- If the temperature in the Flammables Room reaches 90.0° F (32.2° C), all occupants in Birck and the southside of Lownik will be evacuated from the building. No one will be allowed inside the buildings except for fire department personnel, if needed. CHO or designee will contact Campus Safety for evacuations to begin.
- If the temperature in the Flammables Room is 89.9° F (32.1° C) or less, occupants can be in the building and Facilities staff can work in the room to attempt to cool the space down.
- For labs with flammable chemicals (i.e., 372, 3rd floor research labs), if the temperature in those spaces reach 87.0° F (30.6° C), the flammable chemicals will be removed to a different location.

Last Reviewed: 11/27/23